



Photometry

All published luminaire photometric testing performed to IES LM-79-08 standards. To obtain an IES file specific to your project consult: <http://creelighting.com/products/outdoor/canopy-and-soffit/304-series-1#>

PS



ITL Test Report #: 76940
CAN-304-PS-**-06-E-UL-700-40K
Initial Delivered Lumens: 13,581




SFT-304-PS-**-06-E-UL-525-40K
Mounting Height: 15' (4.6m)
Initial Delivered Lumens: 10,576
Initial FC at grade


Petroleum Symmetric Distribution		
LED Count (x10)	4000K	5700K
	Initial Delivered Lumens*	Initial Delivered Lumens*
350mA IC Rated		
04	4,874	5,062
350mA Non-IC Rated		
04	5,130	5,324
06	7,554	7,744
525mA Non-IC Rated		
04	7,181	7,458
06	10,982	11,314
700mA Non-IC Rated		
04	9,056	9,344

* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

SL



ITL Test Report #: 77415
CAN-304-SL-**-06-E-UL-700-40K
Initial Delivered Lumens: 12,768



SFT-304-SL-**-06-E-UL-525-40K
Mounting Height: 15' (4.6m)
Initial Delivered Lumens: 10,231
Initial FC at grade

Sparkle Petroleum Distribution		
LED Count (x10)	4000K	5700K
	Initial Delivered Lumens*	Initial Delivered Lumens*
350mA IC Rated		
04	4,291	4,456
350mA Non-IC Rated		
04	4,962	5,153
06	7,308	7,589
525mA Non-IC Rated		
04	6,947	7,214
06	10,231	10,624
700mA Non-IC Rated		
04	8,436	8,760

* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens